

2430 "E" Street, N. W.
Washington, D. C.
28 August 1953

25X1A9a



25X1A9a

Dear Mr. [REDACTED]:

Returned herewith is Contractor's submission of shop drawing covering reference item.

(strainerless) Upon review of the shop drawing and specifications, our Mechanical Engineer has suggested a reduction of the requirement in line with the attached proposal. He believes that use of the Mon-Log type ejectors may save between two and three hundred dollars. If, in your judgment, a resubmission of the item would cause delay in the work out of proportion with the saving, you are authorized to approve the present submission. In either case, the motors will require to be weatherproof, which is not indicated in the submission.

Other mechanical data sent with this submission are being checked and will follow shortly.

Very truly yours,



25X1A9a

Enclosures